

Sanitary Sewer General Notes:

1. Sanitary sewers shall be installed and accepted in accordance with the Town of Colonie Division of Pure Waters standards, rules and regulations.
2. No sump pump, footing or roof drain shall be connected to any sanitary sewer.
3. All backfill used in trenches located in roadways or parking lots shall be placed in maximum 6-inch lifts and mechanically compacted.
4. When backfilling around existing or new structures, material shall be mechanically compacted in maximum 6-inch lifts.
5. All benchmark elevations are related to National Geodetic Vertical Datum (NGVD) 1929.
6. Sewer mains in relation to water mains: Sewer mains shall be laid at least 10' horizontally from any existing or proposed water main. Vertical separation shall be maintained to provide a minimum of 18" of between the sewer and water main crossing. Where minimum vertical or horizontal separation is not possible, the sanitary sewer pipe shall be upgrade to a water main class pipe.
7. All sanitary sewers shall be installed according to Sewer Improvement Area – SIA # _____.
8. All low pressure sewer piping shall be hydrostatically tested in accordance with the Division of Pure Waters requirements.